

# Montgomery County Public Schools Lead in Drinking Water Testing Report

Laytonsville Elementary School  
21401 Laytonsville Rd  
Laytonsville, MD 20882

Report Date: June 22, 2023

## LEAD IN DRINKING WATER SAMPLE RESULTS SUMMARY

All Maryland public and nonpublic schools are required to sample all drinking water outlets for the presence of lead pursuant to the Code of Maryland Regulations (COMAR). Montgomery County Public Schools (MCPS) is required to remediate outlets where lead in drinking water concentrations exceed the State Action Level (AL) of 5 parts per billion (ppb). A summary of the lead in water initial samples collected by Inspection Experts Inc is presented in the table below.

|                           |         |
|---------------------------|---------|
| Sampling Date             | 3/14/23 |
| # of Outlets Tested       | 36      |
| # of Outlets $\geq$ 5 ppb | 11      |

## NEXT STEPS

If an initial sample exceeds the AL (5 ppb), the outlet will be shut-down within 24 hours, a follow up sample collected, and a remedial plan of action developed for this outlet. No additional sampling or remedial actions are required for schools where all initial samples are below the AL.

## HEALTH EFFECTS OF LEAD

Lead can cause serious health problems if too much enters your body from drinking water or other sources. It can cause damage to the brain and kidneys, and can interfere with the production of red blood cells that carry oxygen to all parts of your body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Lead is stored in the bones and it can be released later in life. During pregnancy, the fetus receives lead from the mother's bones, which may affect brain development. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults.

## **SOURCES OF HUMAN EXPOSURE TO LEAD**

There are many different sources of human exposure to lead. These include: lead-based paint, lead-contaminated dust or soil, some plumbing materials, certain types of pottery, pewter, brass outlets, food, cosmetics, exposure in the workplace and from certain hobbies. According to the Environmental Protection Agency (EPA), 10 to 20 percent of a person's potential exposure to lead may come from drinking water, while for an infant consuming formula mixed with lead containing water this may increase to 40 to 60 percent.

### **TO REDUCE EXPOSURE TO LEAD IN DRINKING WATER:**

1. Run your water to flush out lead: If water hasn't been used for several hours, run water for 15 to 30 seconds or until it becomes cold or reaches a steady temperature before using it for drinking or cooking.
2. Use cold water for cooking and preparing baby formula: Lead from the plumbing dissolves more easily into hot water.

*\*Please note that boiling the water will not reduce lead levels.*

### **ADDITIONAL INFORMATION**

1. For additional information, please contact Brian Mullikin, Environmental Team Leader, at 240.740.2324 or [brian\\_a\\_mullikin@mcpsmd.org](mailto:brian_a_mullikin@mcpsmd.org).
2. For additional information on reducing lead exposure around your home/building and the health effects of lead, visit EPA's website at [www.epa.gov/lead](http://www.epa.gov/lead).
3. If you are concerned about exposure; contact your local health department or healthcare provider to find out how you can get your child tested for lead.

*Please refer to the attachment(s) for additional water sampling information.*

### **Attachment(s):**

A - Lead in Water Sample Results Table

**ATTACHMENT A**

**Lead in Water Sample Results Table**

## Sampling Results for Laytonville ES

| Outlet Barcode | Outlet Location                     | Outlet Type                             | Initial Results (ppb) | Pass/Fail | Status                  |
|----------------|-------------------------------------|-----------------------------------------|-----------------------|-----------|-------------------------|
| LW00682        | In health room                      | Classroom Combination Sink              | <1.0                  | Pass      | Testing Complete        |
| LW00683        | In break room by staff lounge       | Teachers Lounge Sink                    | 2.0                   | Pass      | Testing Complete        |
| LW00707        | In kitchen                          | Kitchen Sink                            | 19.6                  | Fail      | Remediation Action Plan |
| LW00708        | In kitchen                          | Kitchen Sink                            | 4.6                   | Pass      | Testing Complete        |
| LW08086        | In health room                      | Classroom Combination Drinking Fountain | 1.5                   | Pass      | Testing Complete        |
| M32963         | In kitchen                          | Kitchen Sink                            | <1.0                  | Pass      | Testing Complete        |
| M32965         | In kitchen                          | Kitchen Sink                            | 2.8                   | Pass      | Testing Complete        |
| M33339         | In hallway across from staff lounge | Drinking Fountain                       | 4.0                   | Pass      | Testing Complete        |
| M33342         | In classroom CR 3                   | Classroom Combination Drinking Fountain | 3.7                   | Pass      | Testing Complete        |
| M33343         | in classroom 4                      | Classroom Combination Drinking Fountain | 8.8                   | Fail      | Remediation Action Plan |
| M33344         | Classroom 3A                        | Classroom Combination Drinking Fountain | 8.0                   | Fail      | Remediation Action Plan |
| M33345         | In classroom CR 5                   | Classroom Combination Drinking Fountain | 1.2                   | Pass      | Testing Complete        |
| M33346         | In classroom CR 6                   | Classroom Combination Drinking Fountain | 4.7                   | Pass      | Testing Complete        |
| M33347         | In classroom CR 7                   | Classroom Combination Drinking Fountain | 9.4                   | Fail      | Remediation Action Plan |
| M33348         | In classroom CR 8                   | Classroom Combination Drinking Fountain | 3.2                   | Pass      | Testing Complete        |
| M33349         | Classroom 9                         | Classroom Combination Drinking Fountain | 7.1                   | Fail      | Remediation Action Plan |

| <b>Outlet Barcode</b> | <b>Outlet Location</b>           | <b>Outlet Type</b>                      | <b>Initial Results (ppb)</b> | <b>Pass/Fail</b> | <b>Status</b>           |
|-----------------------|----------------------------------|-----------------------------------------|------------------------------|------------------|-------------------------|
| M33350                | In classroom CR 10               | Classroom Combination Drinking Fountain | 4.0                          | Pass             | Testing Complete        |
| M33351                | In classroom CR 11               | Classroom Combination Drinking Fountain | 4.5                          | Pass             | Testing Complete        |
| M33352                | In classroom CR 12               | Classroom Combination Drinking Fountain | 4.7                          | Pass             | Testing Complete        |
| M33353                | In classroom CR 13               | Classroom Combination Drinking Fountain | 7.8                          | Fail             | Remediation Action Plan |
| M33354                | In classroom CR 14               | Classroom Combination Drinking Fountain | 7.6                          | Fail             | Remediation Action Plan |
| M33355                | In hallway near girls bathroom 2 | Drinking Fountain                       | <1.0                         | Pass             | Testing Complete        |
| M33356                | In classroom CR 17               | Classroom Combination Drinking Fountain | 6.8                          | Fail             | Remediation Action Plan |
| M33357                | In classroom CR 16               | Classroom Combination Drinking Fountain | 2.0                          | Pass             | Testing Complete        |
| M33358                | Classroom 15                     | Classroom Combination Drinking Fountain | 2.9                          | Pass             | Testing Complete        |
| M33361                | in classroom 18                  | Fountain                                | 1.3                          | Pass             | Testing Complete        |
| M33362                | In hallway right of music room   | Drinking Fountain                       | 1.9                          | Pass             | Testing Complete        |
| M33365                | In hallway next to gym           | Drinking Fountain                       | 2.9                          | Pass             | Testing Complete        |
| M33367                | Classroom K4                     | Classroom Combination Drinking Fountain | 10.1                         | Fail             | Remediation Action Plan |
| M33368                | In classroom K3                  | Classroom Combination Drinking Fountain | 2.7                          | Pass             | Testing Complete        |
| M33369                | In classroom K2                  | Classroom Combination Drinking Fountain | 5.3                          | Fail             | Remediation Action Plan |
| M33370                | Classroom K1                     | Classroom Combination Drinking Fountain | <1.0                         | Pass             | Testing Complete        |
| M33366                | Mail Room                        | Drinking Fountain                       | 6.3                          | Fail             | Remediation Action Plan |

| <b>Outlet Barcode</b> | <b>Outlet Location</b> | <b>Outlet Type</b> | <b>Initial Results (ppb)</b> | <b>Pass/Fail</b> | <b>Status</b>    |
|-----------------------|------------------------|--------------------|------------------------------|------------------|------------------|
| M33363                | Music Room             | Drinking Fountain  | <1.0                         | Pass             | Testing Complete |
| LW10049               | HWF-Next-Music         | Drinking Fountain  | <1.0                         | Pass             | Testing Complete |
| LW10051               | HWF-Next-Mail Room     | Drinking Fountain  | <1.0                         | Pass             | Testing Complete |

# Montgomery County Public Schools Lead in Drinking Water Testing Report

Laytonsville Elementary School  
21401 Laytonsville Road  
Gaithersburg, MD 20882

Report Date: March 31st, 2020

## LEAD IN DRINKING WATER SAMPLE RESULTS SUMMARY

All Maryland public and nonpublic schools are required to sample all drinking water outlets for the presence of lead pursuant to the Code of Maryland Regulations (COMAR). Montgomery County Public Schools (MCPS) is required to remediate outlets where lead in drinking water concentrations exceed the Montgomery County Action Level (AL) of 5 parts per billion (ppb). A summary of the lead in water initial samples collected by SaLUT are presented in the table below.

|                           |          |
|---------------------------|----------|
| Sampling Date             | 2/4/2020 |
| # of Outlets Tested       | 43       |
| # of Outlets $\geq$ 5 ppb | 1        |

## NEXT STEPS

If an initial sample exceeds the AL (5 ppb), the outlet will be immediately shut-down, a follow-up sample collected, and a remedial plan of action developed for this outlet. No additional sampling or remedial actions are required for schools where all initial samples are below the AL.

## HEALTH EFFECTS OF LEAD

Lead can cause serious health problems if too much enters your body from drinking water or other sources. It can cause damage to the brain and kidneys, and can interfere with the production of red blood cells that carry oxygen to all parts of your body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Lead is stored in the bones and it can be released later in life. During pregnancy, the fetus receives lead from the mother's bones, which may affect brain development. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults.

## **SOURCES OF HUMAN EXPOSURE TO LEAD**

There are many different sources of human exposure to lead. These include: lead-based paint, lead-contaminated dust or soil, some plumbing materials, certain types of pottery, pewter, brass fixtures, food, cosmetics, exposure in the work place and from certain hobbies. According to the Environmental Protection Agency (EPA), 10 to 20 percent of a person's potential exposure to lead may come from drinking water, while for an infant consuming formula mixed with lead-containing water this may increase to 40 to 60 percent.

### **TO REDUCE EXPOSURE TO LEAD IN DRINKING WATER:**

1. Run your water to flush out lead: If water hasn't been used for several hours, run water for 15 to 30 seconds or until it becomes cold or reaches a steady temperature before using it for drinking or cooking.
2. Use cold water for cooking and preparing baby formula: Lead from the plumbing dissolves more easily into hot water.

*\*Please note that boiling the water will not reduce lead levels.*

### **ADDITIONAL INFORMATION**

1. For additional information, please contact Brian Mullikin, Environmental Team Leader, at 240.740.2324 or [brian\\_a\\_mullikin@mcpsmd.org](mailto:brian_a_mullikin@mcpsmd.org).
2. For additional information on reducing lead exposure around your home/building and the health effects of lead, visit EPA's website at [www.epa.gov/lead](http://www.epa.gov/lead).
3. If you are concerned about exposure; contact your local health department or healthcare provider to find out how you can get your child tested for lead.

*Please refer to the attachment(s) for additional water sampling information.*

**Attachment(s)** A – Lead in Water Sample Results Table



**ATTACHMENT A**

**Lead in Water Sample Results Table**

## Sampling Results for Laytonville ES

| Fixture Barode | Fixture Location                    | Fixture Type                            | Initial Results (ppb) | Pass/Fail | Follow up Results (ppb) | Status                  |
|----------------|-------------------------------------|-----------------------------------------|-----------------------|-----------|-------------------------|-------------------------|
| LW00676        | In classroom K2                     | Classroom Combination Sink              | 5.4                   | Fail      | 67.5                    | Remediation Action Plan |
| LW00677        | In classroom K1                     | Classroom Combination Sink              | 1.7                   | Pass      | N/A                     | Testing Complete        |
| LW00678        | In classroom K3                     | Classroom Combination Sink              | 1.2                   | Pass      | N/A                     | Testing Complete        |
| LW00682        | In health room                      | Classroom Combination Sink              | 1.2                   | Pass      | N/A                     | Testing Complete        |
| LW00683        | In break room by staff lounge       | Teachers Lounge Sink                    | <1                    | Pass      | N/A                     | Testing Complete        |
| LW00684        | In classroom CR 1                   | Classroom Combination Sink              | 1.4                   | Pass      | N/A                     | Testing Complete        |
| LW00686        | In classroom CR 3                   | Classroom Combination Sink              | 1.6                   | Pass      | N/A                     | Testing Complete        |
| LW00689        | In classroom CR 5                   | Classroom Combination Sink              | 1.9                   | Pass      | N/A                     | Testing Complete        |
| LW00690        | In classroom CR 6                   | Classroom Combination Sink              | <1                    | Pass      | N/A                     | Testing Complete        |
| LW00691        | In classroom CR 7                   | Classroom Combination Sink              | <1                    | Pass      | N/A                     | Testing Complete        |
| LW00692        | In classroom CR 8                   | Classroom Combination Sink              | 1.3                   | Pass      | N/A                     | Testing Complete        |
| LW00693        | In classroom CR 9                   | Classroom Combination Sink              | 2.5                   | Pass      | N/A                     | Testing Complete        |
| LW00695        | In classroom CR 11                  | Classroom Combination Sink              | 1.4                   | Pass      | N/A                     | Testing Complete        |
| LW00697        | In classroom CR 13                  | Classroom Combination Sink              | 1.2                   | Pass      | N/A                     | Testing Complete        |
| LW00698        | In classroom CR 14                  | Classroom Combination Sink              | 2.0                   | Pass      | N/A                     | Testing Complete        |
| LW00701        | In classroom CR 20                  | Classroom Combination Sink              | <1                    | Pass      | N/A                     | Testing Complete        |
| LW00704        | In classroom CR 17                  | Classroom Combination Sink              | 2.0                   | Pass      | N/A                     | Testing Complete        |
| LW00707        | In kitchen                          | Kitchen Sink                            | <1                    | Pass      | N/A                     | Testing Complete        |
| LW00708        | In kitchen                          | Kitchen Sink                            | 3.7                   | Pass      | N/A                     | Testing Complete        |
| LW08086        | In health room                      | Classroom Combination Drinking Fountain | 2.5                   | Pass      | N/A                     | Testing Complete        |
| M32963         | In kitchen                          | Kitchen Sink                            | 1.0                   | Pass      | N/A                     | Testing Complete        |
| M32965         | In kitchen                          | Kitchen Sink                            | <1                    | Pass      | N/A                     | Testing Complete        |
| M33339         | In hallway across from staff lounge | Drinking Fountain                       | <1                    | Pass      | N/A                     | Testing Complete        |
| M33340         | In classroom CR 1                   | Classroom Combination Drinking Fountain | <1                    | Pass      | N/A                     | Testing Complete        |
| M33341         | In classroom CR 2                   | Classroom Combination Drinking Fountain | 3.9                   | Pass      | N/A                     | Testing Complete        |
| M33342         | In classroom CR 3                   | Classroom Combination Drinking Fountain | <1                    | Pass      | N/A                     | Testing Complete        |
| M33345         | In classroom CR 5                   | Classroom Combination Drinking Fountain | <1                    | Pass      | N/A                     | Testing Complete        |
| M33346         | In classroom CR 6                   | Classroom Combination Drinking Fountain | <1                    | Pass      | N/A                     | Testing Complete        |

|        |                                  |                                         |     |      |     |                  |
|--------|----------------------------------|-----------------------------------------|-----|------|-----|------------------|
| M33347 | In classroom CR 7                | Classroom Combination Drinking Fountain | 1.6 | Pass | N/A | Testing Complete |
| M33348 | In classroom CR 8                | Classroom Combination Drinking Fountain | <1  | Pass | N/A | Testing Complete |
| M33350 | In classroom CR 10               | Classroom Combination Drinking Fountain | <1  | Pass | N/A | Testing Complete |
| M33351 | In classroom CR 11               | Classroom Combination Drinking Fountain | 1.5 | Pass | N/A | Testing Complete |
| M33352 | In classroom CR 12               | Classroom Combination Drinking Fountain | 4.2 | Pass | N/A | Testing Complete |
| M33353 | In classroom CR 13               | Classroom Combination Drinking Fountain | 1.9 | Pass | N/A | Testing Complete |
| M33354 | In classroom CR 14               | Classroom Combination Drinking Fountain | <1  | Pass | N/A | Testing Complete |
| M33355 | In hallway near girls bathroom 2 | Drinking Fountain                       | <1  | Pass | N/A | Testing Complete |
| M33356 | In classroom CR 17               | Classroom Combination Drinking Fountain | 1.9 | Pass | N/A | Testing Complete |
| M33357 | In classroom CR 16               | Classroom Combination Drinking Fountain | 1.5 | Pass | N/A | Testing Complete |
| M33359 | In classroom CR 20               | Classroom Combination Drinking Fountain | 2.3 | Pass | N/A | Testing Complete |
| M33362 | In hallway right of music room   | Drinking Fountain                       | <1  | Pass | N/A | Testing Complete |
| M33365 | In hallway next to gym           | Drinking Fountain                       | <1  | Pass | N/A | Testing Complete |
| M33368 | In classroom K3                  | Classroom Combination Drinking Fountain | <1  | Pass | N/A | Testing Complete |
| M33369 | In classroom K2                  | Classroom Combination Drinking Fountain | <1  | Pass | N/A | Testing Complete |



## **MONTGOMERY COUNTY PUBLIC SCHOOLS LEAD IN DRINKING WATER TESTING 2018**

### **Executive Summary: Laytonsville Elementary School**

21401 Laytonsville Road  
Gaithersburg, MD 20882

|                             |            |
|-----------------------------|------------|
| Date of Test Report:        | 03/12/2018 |
| Round of Testing:           | Initial    |
| # of Outlets Tested:        | 63         |
| # of Outlets $\geq$ 20 ppb: | 0          |
| Low Value (ppb):            | < 1.0      |
| High Value (ppb):           | 19.6       |

### **Project Status**

**Initial testing complete:** All results less than 20 ppb.



March 12, 2018

Mr. Brian Mullikin  
Environmental Team Leader  
Montgomery County Public Schools  
8301 Turkey Thicket Drive  
Building A, First Floor  
Gaithersburg, Maryland 20879

Re: Lead in Water Testing Service

Location: Laytonsville Elementary School  
21401 Laytonsville Road  
Gaithersburg, MD 20882

Dear Mr. Mullikin:

Professional Services Industries (PSI), Inc. is pleased to submit the following report to the Montgomery County Public Schools (MCPS) for completion of initial lead in water testing at Laytonsville Elementary School, located at 21401 Laytonsville Road, Gaithersburg, MD 20882.

**Scope of Services:**

PSI conducted lead in water testing at Laytonsville Elementary School in accordance with the Environmental Protection Agency (EPA) and Maryland House Bill (HB) 270. State regulations established an action level of 20 parts per billion (ppb) to evaluate lead levels in school buildings, a concentration EPA recommends that schools take action to reduce lead below this action level. Maryland regulations requires periodic testing for the presence of lead in drinking water in occupied public and nonpublic school buildings. EPA developed the 3T's (Training, Testing, and Telling) to assist schools in reducing the lead concentrations in their drinking water. More information about 3T's can be found on the EPA website.

PSI visited the site on 02/01/18, 02/02/18, 02/05/18, and 02/06/18 to collect samples from 63 drinking water outlets in accordance with current criteria described by the Maryland Department of the Environment (MDE) Draft Lead in Drinking Water—Public and Nonpublic Schools, Title 26, Subtitle 16 Lead, Chapter 07.

Samples were submitted to a laboratory for lead in water analysis using current US EPA methodology. The laboratory has been certified by the Maryland Department of the Environment to analyze drinking water for lead.

**Results:**

There were no results of the lead in water analysis at or above 20 parts per billion (ppb).

The lead in water sample results < 20 ppb for sample collection date 02/02/18 and 02/06/18 are shown in Attachment A.



**Discussion:**

Lead is a naturally occurring element that can be harmful to humans when ingested or inhaled, particularly to children under the age of six. Lead can adversely affect the development of children's brain potentially leading to detrimental alterations in intelligence and behavior. Lead has been historically used in plumbing, paint and other building materials. Lead is released into the environment from industrial sources and fuel combustion. Lead may also be found in consumer products (imported candy, medicines, toys, dishes, etc.).

Most lead leaches into drinking water from contact with plumbing components such as faucets and valves made of brass or lead-containing solder. The physical and chemical interaction that occurs between the plumbing and water directly contributes to the amount of lead that is released into the water. Although plumbing components installed prior to the 1990's contained more lead than newer materials, the amount of lead in the drinking water cannot be predicted by the age of building. The purpose of this regulation is to establish a program to minimize the risk of exposure to lead in drinking water outlets at schools.

Simple steps like keeping your home clean and well-maintained will go a long way in preventing lead exposure. These steps include inspecting and maintaining all painted surfaces to prevent paint deterioration, using only cold water to prepare food and drinks, flushing water outlets used for drinking or food preparation, and cleaning around painted areas where friction can generate dust, such as doors, windows, and drawers. Wipe these areas with a wet sponge or rag to remove paint chips or dust, and wash children's hands, bottles, pacifiers and toys often.

Respectfully Submitted,

**PROFESSIONAL SERVICE INDUSTRIES, INC.**

Nand Kaushik, P.E.  
Department Manager, Environmental Services  
[Nand.Kaushik@psiusa.com](mailto:Nand.Kaushik@psiusa.com)

Attachments:           A – Lead in Water Test Summary Table

# ATTACHMENT A

## Lead in Water Test Summary Table

**Contractor:** Professional Services Industries, Inc.

**Certified Laboratory:** Microbac Laboratories, Inc.

### Sample Results for Laytonsville Elementary School

| Barcode ID | Room Number | Location                  | Location Notes | Equipment Type | Result (PPB)* | Pass/Fail | Status           |
|------------|-------------|---------------------------|----------------|----------------|---------------|-----------|------------------|
| LW00676    | K2          | Classroom                 |                | Faucet         | <1.0          | Pass      | Testing Complete |
| LW00677    | K1          | Classroom                 |                | Faucet         | <1.0          | Pass      | Testing Complete |
| LW00678    | K3          | Classroom                 |                | Faucet         | 2.8           | Pass      | Testing Complete |
| LW00679    | K4          | Classroom                 |                | Faucet         | 5.7           | Pass      | Testing Complete |
| LW00680    |             | Media Center Media Center | Media Workroom | Faucet         | 6.7           | Pass      | Testing Complete |
| LW00681    |             | Mail Room                 |                | Faucet         | 8.3           | Pass      | Testing Complete |
| LW00682    |             | Health Room               |                | Faucet         | 1.9           | Pass      | Testing Complete |
| LW00683    |             | Break Room                | Staff Lounge   | Faucet         | 3.3           | Pass      | Testing Complete |
| LW00684    | CR 1        | Classroom                 |                | Faucet         | 4.9           | Pass      | Testing Complete |
| LW00685    | CR 2        | Classroom                 |                | Faucet         | 5.5           | Pass      | Testing Complete |
| LW00686    | CR 3        | Classroom                 |                | Faucet         | 3.6           | Pass      | Testing Complete |
| LW00687    | CR 4        | Classroom                 |                | Faucet         | 2.6           | Pass      | Testing Complete |
| LW00688    | CR 3A       | Classroom                 |                | Faucet         | 15.7          | Pass      | Testing Complete |
| LW00689    | CR 5        | Classroom                 |                | Faucet         | 3.1           | Pass      | Testing Complete |
| LW00690    | CR 6        | Classroom                 |                | Faucet         | 2.5           | Pass      | Testing Complete |
| LW00691    | CR 7        | Classroom                 |                | Faucet         | 2.4           | Pass      | Testing Complete |
| LW00692    | CR 8        | Classroom                 |                | Faucet         | 2.4           | Pass      | Testing Complete |
| LW00693    | CR 9        | Classroom                 |                | Faucet         | 4.6           | Pass      | Testing Complete |
| LW00694    | CR 10       | Classroom                 |                | Faucet         | 5.4           | Pass      | Testing Complete |
| LW00695    | CR 11       | Classroom                 |                | Faucet         | 3.5           | Pass      | Testing Complete |
| LW00696    | CR 12       | Classroom                 |                | Faucet         | 5.2           | Pass      | Testing Complete |
| LW00697    | CR 13       | Classroom                 |                | Faucet         | 4.8           | Pass      | Testing Complete |

| Barcode ID | Room Number | Location  | Location Notes           | Equipment Type   | Result (PPB)* | Pass/Fail | Status           |
|------------|-------------|-----------|--------------------------|------------------|---------------|-----------|------------------|
| LW00698    | CR 14       | Classroom |                          | Faucet           | 2.4           | Pass      | Testing Complete |
| LW00699    | CR 18       | Classroom |                          | Faucet           | 17.7          | Pass      | Testing Complete |
| LW00700    | CR 19       | Classroom |                          | Faucet           | 5.2           | Pass      | Testing Complete |
| LW00701    | CR 20       | Classroom |                          | Faucet           | 3.3           | Pass      | Testing Complete |
| LW00702    | CR 15       | Classroom |                          | Faucet           | 8.2           | Pass      | Testing Complete |
| LW00703    | CR 16       | Classroom |                          | Faucet           | 5             | Pass      | Testing Complete |
| LW00704    | CR 17       | Classroom |                          | Faucet           | 2.9           | Pass      | Testing Complete |
| LW00705    |             | Music     |                          | Faucet           | 13.1          | Pass      | Testing Complete |
| LW00706    |             | Classroom | Resource 3               | Faucet           | 19.6          | Pass      | Testing Complete |
| LW00707    |             | Kitchen   |                          | Faucet           | <1.0          | Pass      | Testing Complete |
| LW00708    |             | Kitchen   |                          | Faucet           | 1.9           | Pass      | Testing Complete |
| M32963     |             | Kitchen   |                          | Faucet           | 2.8           | Pass      | Testing Complete |
| M32965     |             | Kitchen   |                          | Faucet           | 1.1           | Pass      | Testing Complete |
| M33339     |             | Hallway   | Across From Staff Lounge | Cooler           | <1.0          | Pass      | Testing Complete |
| M33340     | CR 1        | Classroom |                          | Bubbler - Indoor | 4.7           | Pass      | Testing Complete |
| M33341     | CR 2        | Classroom |                          | Bubbler - Indoor | 1.7           | Pass      | Testing Complete |
| M33342     | CR 3        | Classroom |                          | Bubbler - Indoor | 1.2           | Pass      | Testing Complete |
| M33344     | CR 3A       | Classroom |                          | Bubbler - Indoor | 8.3           | Pass      | Testing Complete |
| M33345     | CR 5        | Classroom |                          | Bubbler - Indoor | 1.8           | Pass      | Testing Complete |
| M33346     | CR 6        | Classroom |                          | Bubbler - Indoor | 2.3           | Pass      | Testing Complete |
| M33347     | CR 7        | Classroom |                          | Bubbler - Indoor | 1.1           | Pass      | Testing Complete |
| M33348     | CR 8        | Classroom |                          | Bubbler - Indoor | 1.6           | Pass      | Testing Complete |
| M33349     | CR 9        | Classroom |                          | Bubbler - Indoor | 3.6           | Pass      | Testing Complete |
| M33350     | CR 10       | Classroom |                          | Bubbler - Indoor | 2.4           | Pass      | Testing Complete |
| M33351     | CR 11       | Classroom |                          | Bubbler - Indoor | 1.2           | Pass      | Testing Complete |
| M33352     | CR 12       | Classroom |                          | Bubbler - Indoor | 2.1           | Pass      | Testing Complete |
| M33353     | CR 13       | Classroom |                          | Bubbler - Indoor | 2.2           | Pass      | Testing Complete |
| M33354     | CR 14       | Classroom |                          | Bubbler - Indoor | 1.7           | Pass      | Testing Complete |



| Barcode ID | Room Number | Location  | Location Notes      | Equipment Type   | Result (PPB)* | Pass/Fail | Status           |
|------------|-------------|-----------|---------------------|------------------|---------------|-----------|------------------|
| M33356     | CR 17       | Classroom |                     | Bubbler - Indoor | 1.7           | Pass      | Testing Complete |
| M33357     | CR 16       | Classroom |                     | Bubbler - Indoor | 2             | Pass      | Testing Complete |
| M33358     | CR 15       | Classroom |                     | Bubbler - Indoor | 3.9           | Pass      | Testing Complete |
| M33359     | CR 20       | Classroom |                     | Bubbler - Indoor | 4.7           | Pass      | Testing Complete |
| M33361     | CR 18       | Classroom |                     | Bubbler - Indoor | 13.9          | Pass      | Testing Complete |
| M33362     |             | Hallway   | Right Of Music Room | Faucet           | <1.0          | Pass      | Testing Complete |
| M33363     |             | Music     |                     | Bubbler - Indoor | 5.2           | Pass      | Testing Complete |
| M33364     |             | Classroom | Resource 3          | Bubbler - Indoor | 12.3          | Pass      | Testing Complete |
| M33365     |             | Hallway   | Next To Gym         | Cooler           | <1.0          | Pass      | Testing Complete |
| M33367     | K4          | Classroom |                     | Bubbler - Indoor | 11.1          | Pass      | Testing Complete |
| M33368     | K3          | Classroom |                     | Bubbler - Indoor | 3             | Pass      | Testing Complete |
| M33369     | K2          | Classroom |                     | Bubbler - Indoor | 4.3           | Pass      | Testing Complete |
| M33370     | K1          | Classroom |                     | Bubbler - Indoor | 8.8           | Pass      | Testing Complete |

\*ppb = parts per billion