

Montgomery County Public Schools Lead in Drinking Water Testing Report

**Parkland Middle School
4610 West Frankfort Drive
Rockville, MD 20853**

Report Date: July 28th, 2023

LEAD IN DRINKING WATER SAMPLE RESULTS SUMMARY

All Maryland public and nonpublic schools are required to sample all drinking water outlets for the presence of lead pursuant to the Code of Maryland Regulations (COMAR). Montgomery County Public Schools (MCPS) is required to remediate outlets where lead in drinking water concentrations exceed the State Action Level (AL) of 5 parts per billion (ppb). A summary of the lead in water initial samples collected by Inspection Experts Inc. is presented in the table below.

| | |
|---------------------------|---------|
| Sampling Date | 3/24/23 |
| # of Outlets Tested | 26 |
| # of Outlets \geq 5 ppb | 1 |

NEXT STEPS

If an initial sample exceeds the AL (5 ppb), the outlet will be shut-down within 24 hours, a follow up sample collected, and a remedial plan of action developed for this outlet. No additional sampling or remedial actions are required for schools where all initial samples are below the AL.

HEALTH EFFECTS OF LEAD

Lead can cause serious health problems if too much enters your body from drinking water or other sources. It can cause damage to the brain and kidneys, and can interfere with the production of red blood cells that carry oxygen to all parts of your body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Lead is stored in the bones and it can be released later in life. During pregnancy, the fetus receives lead from the mother's bones, which may affect brain development. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults.

SOURCES OF HUMAN EXPOSURE TO LEAD

There are many different sources of human exposure to lead. These include: lead-based paint, lead-contaminated dust or soil, some plumbing materials, certain types of pottery, pewter, brass outlets, food, cosmetics, exposure in the workplace and from certain hobbies. According to the Environmental Protection Agency (EPA), 10 to 20 percent of a person's potential exposure to lead may come from drinking water, while for an infant consuming formula mixed with lead containing water this may increase to 40 to 60 percent.

TO REDUCE EXPOSURE TO LEAD IN DRINKING WATER:

1. Run your water to flush out lead: If water hasn't been used for several hours, run water for 15 to 30 seconds or until it becomes cold or reaches a steady temperature before using it for drinking or cooking.
2. Use cold water for cooking and preparing baby formula: Lead from the plumbing dissolves more easily into hot water.

**Please note that boiling the water will not reduce lead levels.*

ADDITIONAL INFORMATION

1. For additional information, please contact Brian Mullikin, Environmental Team Leader, at 240.740.2324 or brian_a_mullikin@mcpsmd.org.
2. For additional information on reducing lead exposure around your home/building and the health effects of lead, visit EPA's website at www.epa.gov/lead.
3. If you are concerned about exposure; contact your local health department or healthcare provider to find out how you can get your child tested for lead.

Please refer to the attachment(s) for additional water sampling information.

Attachment(s):

A - Lead in Water Sample Results Table

ATTACHMENT A

Lead in Water Sample Results Table

Sampling Results for Parkland MS

| Outlet Barcode | Outlet Location | Outlet Type | Initials Results (ppb) | Pass/Fail | Status |
|----------------|---|--------------------|------------------------|-----------|------------------|
| LW02735 | In kitchen | Kitchen Sink | <1.0 | Pass | Testing Complete |
| LW02736 | In kitchen | Kitchen Sink | <1.0 | Pass | Testing Complete |
| LW02786 | In kitchen | Kitchen Sink | <1.0 | Pass | Testing Complete |
| LW08073 | In Boys locker room 1123 | Drinking Fountain | <1.0 | Pass | Testing Complete |
| LW08074 | In Boys locker room 1123 | Drinking Fountain | <1.0 | Pass | Testing Complete |
| LW08075 | In girls locker room 1117 | Drinking Fountain | <1.0 | Pass | Testing Complete |
| LW08076 | Girls Locker Room | Drinking Fountain | <1.0 | Pass | Testing Complete |
| LW08077 | In hallway adjacent to classroom 1020A | Drinking Fountain | <1.0 | Pass | Testing Complete |
| LW08078 | In hallway adjacent from boys restroom 1006 | Drinking Fountain | <1.0 | Pass | Testing Complete |
| M07485 | In health room 1201 | Nurses Office Sink | <1.0 | Pass | Testing Complete |
| M07490 | In hallway next to health 1201 | Drinking Fountain | <1.0 | Pass | Testing Complete |
| M07491 | In hallway next to health 1201 | Drinking Fountain | <1.0 | Pass | Testing Complete |
| M07492 | In work room 1209B by media center | Classroom Sink | <1.0 | Pass | Testing Complete |
| M07501 | In hallway across from 1020A | Drinking Fountain | <1.0 | Pass | Testing Complete |
| M07502 | In hallway across from 1020A | Drinking Fountain | <1.0 | Pass | Testing Complete |
| M07524 | In hallway across from 1006 BBR | Drinking Fountain | <1.0 | Pass | Testing Complete |

| Outlet Barcode | Outlet Location | Outlet Type | Initials Results (ppb) | Pass/Fail | Status |
|-----------------------|----------------------------------|--------------------|-------------------------------|------------------|-------------------------|
| M07525 | In hallway across from 1006 BBR | Drinking Fountain | <1.0 | Pass | Testing Complete |
| M07816 | In kitchen | Kitchen Sink | <1.0 | Pass | Testing Complete |
| M07817 | In kitchen | Ice Machine | <1.0 | Pass | Testing Complete |
| M07819 | In kitchen 1109 | Kitchen Sink | <1.0 | Pass | Testing Complete |
| M07821 | In kitchen | Kitchen Sink | <1.0 | Pass | Testing Complete |
| M07823 | In kitchen | Kitchen Sink | <1.0 | Pass | Testing Complete |
| M07834 | In hallway between 1301 and 1303 | Drinking Fountain | <1.0 | Pass | Testing Complete |
| LW11756 | HW Between Rm. 2005 & Rm. 2007 | Drinking Fountain | <1.0 | Pass | Testing Complete |
| LW0876 | HW Between Rm. 2005 & Rm. 2007 | Drinking Fountain | <1.0 | Pass | Testing Complete |
| M07488 | Health Room | Nurses Office Sink | 6.0 | Fail | Remediation Action Plan |

Montgomery County Public Schools Lead in Drinking Water Testing Report

**Parkland Middle School
4610 West Frankfort Drive
Rockville, MD 20853**

Report Date: March 16th, 2020

LEAD IN DRINKING WATER SAMPLE RESULTS SUMMARY

All Maryland public and nonpublic schools are required to sample all drinking water outlets for the presence of lead pursuant to the Code of Maryland Regulations (COMAR). Montgomery County Public Schools (MCPS) is required to remediate outlets where lead in drinking water concentrations exceed the Montgomery County Action Level (AL) of 5 parts per billion (ppb). A summary of the lead in water initial samples collected by SaLUT are presented in the table below.

| | |
|---------------------------|-----------|
| Sampling Date | 2/12/2020 |
| # of Outlets Tested | 34 |
| # of Outlets \geq 5 ppb | 1 |

NEXT STEPS

If an initial sample exceeds the AL (5 ppb), the outlet will be immediately shut-down, a follow-up sample collected, and a remedial plan of action developed for this outlet. Due to the Stay-at-Home Order to combat the spread of COVID-19 (coronavirus), no follow-up samples were collected. No additional sampling or remedial actions are required for schools where all initial samples are below the AL.

HEALTH EFFECTS OF LEAD

Lead can cause serious health problems if too much enters your body from drinking water or other sources. It can cause damage to the brain and kidneys, and can interfere with the production of red blood cells that carry oxygen to all parts of your body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Lead is stored in the bones and it can be released later in life. During pregnancy, the fetus receives lead from the mother's bones, which may affect brain development. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults.

SOURCES OF HUMAN EXPOSURE TO LEAD

There are many different sources of human exposure to lead. These include: lead-based paint, lead-contaminated dust or soil, some plumbing materials, certain types of pottery, pewter, brass fixtures, food, cosmetics, exposure in the work place and from certain hobbies. According to the Environmental Protection Agency (EPA), 10 to 20 percent of a person's potential exposure to lead may come from drinking water, while for an infant consuming formula mixed with lead-containing water this may increase to 40 to 60 percent.

TO REDUCE EXPOSURE TO LEAD IN DRINKING WATER:

1. Run your water to flush out lead: If water hasn't been used for several hours, run water for 15 to 30 seconds or until it becomes cold or reaches a steady temperature before using it for drinking or cooking.
2. Use cold water for cooking and preparing baby formula: Lead from the plumbing dissolves more easily into hot water.

**Please note that boiling the water will not reduce lead levels.*

ADDITIONAL INFORMATION

1. For additional information, please contact Brian Mullikin, Environmental Team Leader, at 240.740.2324 or brian_a_mullikin@mcpsmd.org.
2. For additional information on reducing lead exposure around your home/building and the health effects of lead, visit EPA's website at www.epa.gov/lead.
3. If you are concerned about exposure; contact your local health department or healthcare provider to find out how you can get your child tested for lead.

Please refer to the attachment(s) for additional water sampling information.

Attachment(s) A – Lead in Water Sample Results Table

ATTACHMENT A

Lead in Water Sample Results Table

Sampling Results for Parkland MS

| Fixture Barcode | Fixture Location | Fixture Type | Initial Results (ppb) | Pass/Fail | Follow up Results (ppb) | Status |
|-----------------|---|--------------------|-----------------------|-----------|-------------------------|------------------|
| LW02670 | In conference room 2003 | Classroom Sink | <1 | Pass | N/A | Testing complete |
| LW02735 | In kitchen | Kitchen Sink | <1 | Pass | N/A | Testing complete |
| LW02736 | In kitchen | Kitchen Sink | <1 | Pass | N/A | Testing complete |
| LW02786 | In kitchen | Kitchen Sink | <1 | Pass | N/A | Testing complete |
| M07485 | In health room 1201 by health | Nurses Office Sink | <1 | Pass | N/A | Testing complete |
| M07490 | In hallway next to health 1201 | Drinking Fountain | <1 | Pass | N/A | Testing complete |
| M07491 | In hallway next to health 1201 | Drinking Fountain | <1 | Pass | N/A | Testing complete |
| M07492 | In work room 1209B by media center ie. inside IMC | Classroom Sink | <1 | Pass | N/A | Testing complete |
| M07493 | In conference 1221 | Classroom Sink | <1 | Pass | N/A | Testing complete |
| M07494 | In break room 1222 | Classroom Sink | <1 | Pass | N/A | Testing complete |
| M07496 | In classroom 1225 | Classroom Sink | <1 | Pass | N/A | Testing complete |
| M07501 | In hallway across from 1020A | Drinking Fountain | <1 | Pass | N/A | Testing complete |
| M07502 | In hallway across from 1020A | Drinking Fountain | <1 | Pass | N/A | Testing complete |
| M07505 | In classroom 1011 | Classroom Sink | 1.3 | Pass | N/A | Testing complete |
| M07524 | In hallway across from 1006 BBR | Drinking Fountain | <1 | Pass | N/A | Testing complete |
| M07525 | In hallway across from 1006 BBR | Drinking Fountain | <1 | Pass | N/A | Testing complete |
| M07536 | In work room 1000B | Classroom Sink | <1 | Pass | N/A | Testing complete |
| M07539 | In conference 1311 | Classroom Sink | <1 | Pass | N/A | Testing complete |
| M07540 | In conference 1404 | Classroom Sink | <1 | Pass | N/A | Testing complete |
| M07791 | In hallway between 2021 and 2023 | Drinking Fountain | <1 | Pass | N/A | Testing complete |
| M07801 | In conference room 2013 | Classroom Sink | <1 | Pass | N/A | Testing complete |
| M07816 | In kitchen by kitchen | Kitchen Sink | <1 | Pass | N/A | Testing complete |
| M07817 | In kitchen by kitchen | Ice Machine | <1 | Pass | N/A | Testing complete |

| | | | | | | |
|---------|---|-------------------|-----|------|-----|----------------------------|
| M07819 | In kitchen 1109 | Kitchen Sink | 5.0 | Fail | NC | Remediation Action Plan |
| M07821 | In kitchen | Kitchen Sink | <1 | Pass | N/A | Testing complete |
| M07823 | In kitchen by kitchen | Kitchen Sink | <1 | Pass | N/A | Testing complete |
| M07834 | In hallway between 1301 and 1303 | Drinking Fountain | <1 | Pass | N/A | Testing complete |
| LW08073 | In Boys locker room 1123 | Drinking Fountain | <1 | Pass | N/A | Testing complete |
| LW08074 | In Boys locker room 1123 | Drinking Fountain | <1 | Pass | N/A | Testing complete |
| LW08075 | In girls locker room 1117 | Drinking Fountain | <1 | Pass | N/A | Testing complete |
| LW08076 | Girls Locker Room | Drinking Fountain | <1 | Pass | N/A | Testing complete |
| LW08077 | In hallway adjacent to classroom 1020A | Drinking Fountain | <1 | Pass | N/A | Testing complete |
| LW08078 | In hallway adjacent from boys restroom 1006 | Drinking Fountain | <1 | Pass | N/A | Testing complete |
| LW08079 | In hallway adjacent from classroom 2006 | Drinking Fountain | <1 | Pass | N/A | Testing complete |

NC - Not Collected (No follow-up sample collected due to COVID-19 (Coronavirus) Stay-at-Home Order.)



Montgomery County Public Schools Lead in Drinking Water Post-Remediation Follow-Up Testing 2019

August 30, 2019

Executive Summary:

Parkland Middle School

4610 West Frankfort Drive

Rockville, Maryland 20853

| | |
|----------------------------|----------------------------|
| Round of Testing: | Post-Remediation Follow-up |
| Sample Date | 1/30/19 |
| # of Outlets Tested: | 1 |
| # of Outlets ≥ 5 ppb: | 0 |
| Low Value (ppb): | <1.0 |
| High Value (ppb): | <1.0 |

Project Status

Testing Complete: Post-remediation follow-up testing completed for following rooms:

Kitchen 1109 - Outlet (M07819) will be placed back into service



August 30, 2019

Mr. Brian Mullikin, MS
Environmental Team Leader
Montgomery County Public Schools
8301 Turkey Thicket Dr., Bldg A, 1st Floor
Gaithersburg, Maryland 20879

Re: Lead in Water Post-Remediation Follow-up Testing Service

Location: Parkland Middle School

4610 West Frankfort Drive
Rockville, Maryland 20853

Dear Mr. Mullikin:

KCI Technologies, Inc. (KCI) is pleased to submit the following report to the Montgomery County Public Schools (MCPS) for completion of the post-remediation follow-up lead in water testing at Parkland Middle School, located at 4610 West Frankfort Drive in Rockville, Maryland 20853.

SCOPE OF SERVICES

One drinking water outlet was remediated at Parkland Middle School due to initial lead levels that exceeded the lead action level of 5 parts per billion (ppb). KCI Technologies, Inc. conducted lead in water post-remediation follow-up testing in accordance with the Maryland Code of Regulations (COMAR) 26.16.07 - Lead in Drinking Water - Public and Nonpublic Schools.

KCI Technologies, Inc. visited the site on 1/30/19 to collect a post-remediation follow-up sample from 1 drinking water outlet that had been replaced. The sample was submitted to a laboratory for lead in water analysis using current US EPA methodology. The laboratory has been certified by the Maryland Department of the Environment to analyze drinking water for lead.

RESULTS

The initial, flush, and post-remediation follow-up results are highlighted in the summary table below:

| Barcode ID | Room Number | Location | Notes | Equipment Type | Initial (ppb) | Flush (ppb) | Post-Remediation Follow-up (ppb) | Post-Remediation Follow-up Pass/Fail | Status |
|------------|-------------|----------|-------|----------------|---------------|-------------|----------------------------------|--------------------------------------|--|
| M07819 | 1109 | Kitchen | | Faucet | 33.9 | 37.7 | <1.0 | Pass | Post-remediation follow-up testing complete. Outlet will be placed back into service |

DISCUSSION

Lead is a naturally occurring element that can be harmful to humans when ingested or inhaled, particularly to children under the age of six. Lead can adversely affect the development of children's brain potentially leading to detrimental alterations in intelligence and behavior. Lead has been historically used in plumbing, paint and other building materials. Lead is released into the environment from industrial sources and fuel combustion. Lead may also be found in consumer products (imported candy, medicines, toys, dishes, etc.).

Most lead leaches into drinking water from contact with plumbing components such as faucets and valves made of brass or lead-containing solder. The physical and chemical interaction that occurs between the plumbing and water directly contributes to the amount of lead that is released into the water. Although plumbing components installed prior to the 1990's could contain more lead than newer materials, the amount of lead in the drinking water cannot be predicted by the age of building. The purpose of this regulation is to establish a program to minimize the risk of exposure to lead in drinking water outlets at schools. The Environmental Protection Agency (EPA) developed the 3T's (Training, Testing, and Telling) to assist schools in reducing the lead concentrations in their drinking water. More information about 3T's can be found on the EPA website.

Simple steps like keeping your home clean and well-maintained will go a long way in preventing lead exposure. These steps include inspecting and maintaining all painted surfaces to prevent paint deterioration, using only cold water to prepare food and drinks, flushing water outlets used for drinking or food preparation, and cleaning around painted areas where friction can generate dust, such as doors, windows, and drawers. Wipe these areas with a wet sponge or rag to remove paint chips or dust, and wash children's hands, bottles, pacifiers and toys often.

Respectfully Submitted,
KCI Technologies, Inc.



Kamau McAbee
MDE Certified Water Sampler #8281KM
KCI Job #1214634186



Montgomery County Public Schools Lead in Drinking Water Testing 2018

April 27, 2018

Executive Summary:

Parkland Middle School

4610 West Frankfort Drive

Rockville, Maryland 20853

| | |
|--|--------------------|
| Date of Test Report: | April 27, 2018 |
| Round of Testing: | Initial |
| # of Outlets Tested: | 29 |
| # of Outlets ≥ 20 ppb: | 1 |
| Low Value (ppb): | <1.0 |
| High Value (ppb): | 33.9 |
| Follow-Up Testing Required (Samples ≥ 20 ppb): | Kitchen (37.7 ppb) |

| | |
|----------------------|-------------------------|
| Round of Testing: | Follow-Up - 30 sec draw |
| # of Outlets Tested: | 1 |

Project Status:

Testing Complete: Remediation Plan

Kitchen - Replace fixture (M07819), in addition to supply line and valve located under sink



April 27, 2018

Mr. Brian Mullikin, MS
Environmental Team Leader
Montgomery County Public Schools
Division of Maintenance
Gaithersburg, Maryland 20879

Re: Drinking Water Testing

KCI Job #1214634186

Location: Parkland Middle School

4610 West Frankfort Drive
Rockville, Maryland 20853

Dear Mr. Mullikin:

KCI Technologies, Inc. (KCI) is pleased to submit the following report to the Montgomery County Public Schools (MCPS) for completion of initial and follow-up lead in water testing at Parkland Middle School, located at 4610 West Frankfort Drive in Rockville, Maryland 20853.

SCOPE OF SERVICES

KCI conducted lead in water testing at Parkland Middle School in accordance with the Environmental Protection Agency (EPA) and Maryland House Bill (HB) 270. State regulation established an action level of 20 parts per billion (ppb) to evaluate lead levels in school buildings, a concentration EPA recommends that schools take action to reduce lead below this action level. Maryland requires periodic testing for the presence of lead in drinking water in occupied public and nonpublic school buildings. EPA developed the 3T's (Training, Testing, and Telling) to assist schools in reducing the lead concentrations in their drinking water. More information about 3T's can be found on the EPA website.

KCI visited the site on 2/1/2018 and 2/2/2018 to collect samples from 29 drinking water outlets in accordance with current criteria described by the Maryland Department of the Environment (MDE) Draft Lead in Drinking Water - Public and Nonpublic Schools, Title 26, Subtitle 16 Lead, Chapter 07. On 4/11/2018, one 30 second follow-up sample was collected.

Samples were submitted to a laboratory for lead in water analysis using current US EPA methodology. The laboratory has been certified by the Maryland Department of the Environment to analyze drinking water for lead.

RESULTS

There was one result of the lead in water analysis at or above 20 parts per billion (ppb) and subsequent follow up 30 second results are highlighted in the summary table below:

| Barcode ID | Sample Location | Date Collected | Initial Sample Result (ppb) | Date Collected | 30 Second Follow Up Sample Result (ppb) |
|-------------------|------------------------|-----------------------|------------------------------------|-----------------------|--|
| M07819 | Faucet - Kitchen | 2/2/2018 | 33.9 | 4/11/2018 | 37.7 |

The initial lead in water sample results (2/2/2018) and 30 second follow up results (4/11/2018) are shown in Attachment A.

DISCUSSION

Lead is a naturally occurring element that can be harmful to humans when ingested or inhaled, particularly to children under the age of six. Lead can adversely affect the development of children's brain potentially leading to detrimental alterations in intelligence and behavior. Lead has been historically used in plumbing, paint and other building materials. Lead is released into the environment from industrial sources and fuel combustion. Lead may also be found in consumer products (imported candy, medicines, toys, dishes, etc.).

Most lead leaches into drinking water from contact with plumbing components such as faucets and valves made of brass or lead-containing solder. The physical and chemical interaction that occurs between the plumbing and water directly contributes to the amount of lead that is released into the water. Although plumbing components installed prior to the 1990's could contain more lead than newer materials, the amount of lead in the drinking water cannot be predicted by the age of building. The purpose of this regulation is to establish a program to minimize the risk of exposure to lead in drinking water outlets at schools.

Simple steps like keeping your home clean and well-maintained will go a long way in preventing lead exposure. These steps include inspecting and maintaining all painted surfaces to prevent paint deterioration, using only cold water to prepare food and drinks, flushing water outlets used for drinking or food preparation, and cleaning around painted areas where friction can generate dust, such as doors, windows, and drawers. Wipe these areas with a wet sponge or rag to remove paint chips or dust, and wash children's hands, bottles, pacifiers and toys often.

Respectfully Submitted,
KCI Technologies, Inc.



Kamau McAbee
MDE Certified Water Sampler #8281KM

Attachment:

A- Lead in Water Test Summary Table

ATTACHMENT A

Lead in Water Test Summary Table

ATTACHMENT A

Lead in Water Test Summary Table

Contractor: KCI Technologies, Inc.

Certified Laboratory: Microbac Laboratories, Inc.

Initial Sample Result for Parkland Middle School

| Barcode ID | Room # | Location | Location Notes | Equipment Type | Results (PPB)* | Pass/Fail | Status |
|------------|--------|------------------------|-----------------------------|----------------|----------------|-----------|--------------------------|
| LW02670 | 2003 | Conference Room | | Faucet | <1.0 | Pass | Testing Complete |
| LW02735 | | Kitchen | | Faucet | <1.0 | Pass | Testing Complete |
| LW02736 | | Kitchen | | Faucet | <1.0 | Pass | Testing Complete |
| LW02786 | | Kitchen | | Faucet | <1.0 | Pass | Testing Complete |
| M07485 | 1201 | Health Room | | Faucet | <1.0 | Pass | Testing Complete |
| M07488 | 1201D | Exam Health | | Faucet | 6.0 | Pass | Testing Complete |
| M07490 | | Hallway | Next to Health 1201 | Cooler | <1.0 | Pass | Testing Complete |
| M07491 | | Hallway | Next to Health 1201 | Cooler | <1.0 | Pass | Testing Complete |
| M07492 | 1209B | Work Room Media Center | inside IMC | Faucet | 1.0 | Pass | Testing Complete |
| M07493 | 1221 | Conference | | Faucet | <1.0 | Pass | Testing Complete |
| M07494 | 1222 | Break Room | | Faucet | <1.0 | Pass | Testing Complete |
| M07496 | 1225 | Classroom | | Faucet | <1.0 | Pass | Testing Complete |
| M07501 | | Hallway | Across from Rm 1020A | Cooler | <1.0 | Pass | Testing Complete |
| M07502 | | Hallway | Across from Rm 1020A | Cooler | <1.0 | Pass | Testing Complete |
| M07505 | 1011 | Classroom | | Faucet | 1.0 | Pass | Testing Complete |
| M07524 | | Hallway | Across from 1006 BBR | Cooler | <1.0 | Pass | Testing Complete |
| M07525 | | Hallway | Across from 1006 BBR | Cooler | <1.0 | Pass | Testing Complete |
| M07536 | 1000B | Work Room | | Faucet | <1.0 | Pass | Testing Complete |
| M07539 | 1311 | Conference | | Faucet | <1.0 | Pass | Testing Complete |
| M07540 | 1404 | Conference | | Faucet | <1.0 | Pass | Testing Complete |
| M07791 | | Hallway | Between Rm 2021 and 2023 | Cooler | <1.0 | Pass | Testing Complete |
| M07801 | 2013 | Conference Room | | Faucet | 1.4 | Pass | Testing Complete |
| M07816 | | Kitchen | | Faucet | <1.0 | Pass | Testing Complete |
| M07817 | | Kitchen | | Ice Maker | <1.0 | Pass | Testing Complete |
| M07819 | | Kitchen | | Faucet | 33.9 | Fail | Follow-up Testing Needed |
| M07821 | | Kitchen | | Faucet | <1.0 | Pass | Testing Complete |
| M07823 | | Kitchen | | Faucet | <1.0 | Pass | Testing Complete |
| M07833 | | Hallway | Between Rm 1301 and Rm 1303 | Cooler | <1.0 | Pass | Testing Complete |

| Barcode ID | Room # | Location | Location Notes | Equipment Type | Results (PPB)* | Pass/Fail | Status |
|------------|--------|----------|-----------------------------|----------------|----------------|-----------|------------------|
| M07834 | | Hallway | Between Rm 1301 and Rm 1303 | Cooler | <1.0 | Pass | Testing Complete |

*PPB = Parts per billion

Contractor: KCI Technologies, Inc.
Certified Laboratory: Microbac Laboratories, Inc.

Follow Up Sample Result for Parkland Middle School

| Barcode ID | Room # | Location | Equipment Type | Initial Draw (2nd) (PPB) | Initial Draw (3rd) (PPB) | 30 Second Draw (PPB)* | Status |
|------------|--------|----------|----------------|--------------------------|--------------------------|-----------------------|---|
| M07819 | | Kitchen | Faucet | 93.7 | 49.7 | 37.7 | Remediation required – replace fixture, in addition to supply line and valve located under sink |

*PPB = parts per billion

Note: Fixture(s) with elevated test results were immediately removed from service. Subsequent 2nd and 3rd round testing was performed on these fixture(s) for further diagnostics for remediation. Because the fixture was shut off after the first test, the subsequent test results may not be representative of an in-use fixture because of stagnant water in the supply line and the operation of shut off valves prior to the tests. All fixtures with elevated test results are to be remediated. After remediation, post remediation testing will be conducted before the fixture is returned to service.